

TREATMENT OF COOLING WATER SYSTEMS (SUCH AS COOLING TOWERS, EVAPORATIVE CONDENSERS)

General Information

DIRECTIONS FOR USE

SaniDate 5.0 Sanitizer/Disinfectant works best when diluted with water containing minimal levels of organic or inorganic materials, and with water having a neutral pH. Thoroughly rinse out tank with water before mixing concentrate. This product will readily mix with clean, neutral water and does not require agitation.

SaniDate 5.0 Sanitizer/Disinfectant concentrate should not be combined or mixed with any other pesticide concentrates.

This product is not for use on medical device surfaces.

Before use in federally inspected meat and poultry food processing plants and dairies, food products and packaging materials must be removed from room or carefully protected. A potable water rinse is not allowed (Do not rinse) following use of the product as a sanitizer on previously cleaned hard surfaces provided that the surfaces are adequately drained before contact with food so that little or no residue remains.

Limitations, Restrictions, and Exceptions

TREATMENT OF COOLING WATER SYSTEMS (SUCH AS COOLING TOWERS, EVAPORATIVE CONDENSERS)

Severely fouled systems should be cleaned before treatment. Discontinue use of chlorine or bromine products prior to using this product. SaniDate 5.0 Sanitizer/Disinfectant should be added to the system directly and not mixed with other chemicals or additives prior to dosing. Other chemicals should be added separately. Check compatibility of SaniDate 5.0 Sanitizer/Disinfectant with any other chemicals or additives prior to use. Contamination with certain chemicals could result in lack of efficacy. Add SaniDate 5.0 Sanitizer/Disinfectant at a point in the system where uniform mixing and even distribution will occur such as the cooling tower basin sump. Shock doses may be applied for 1 to 2 hours, as

necessary, whereas intermittent doses are applied for 5 to 60 minutes 1 to 100 times per day. For either shock, intermittent or continuous dosing, apply 3.2 fl oz to 22.5 fl. oz. of SaniDate 5.0 Sanitizer/Disinfectant solution per 1,000 gallons of water. This will provide 25 to 175 ppm of SaniDate 5.0 Sanitizer/Disinfectant, or 1 to 9 ppm of peroxyacetic acid. Repeat treatment as required to maintain control.

Method

[Spray](#)

Rates

[field_rates 0](#)

[field_rates 1](#)

[field_rates 2](#)

•

Timings

[N.A.](#)