

INDOOR CLOSED LOOP, NON-POTABLE, NON-FOOD CONTACT WATER SYSTEMS: TREATMENT OF RAW AND PROCESS WATER (SHOCK OR INTERMITTENT DOSING)

General Information

DIRECTIONS FOR USE

CONTROL OF ALGAL, FUNGAL, AND BACTERIAL GROWTH IN PULP AND PAPER MILL SYSTEMS FOR FOOD AND NON-FOOD CONTACT PAPER

Proxitane WW -12 provides an effective means to treat various process waters for slime control. Dosage rates should be increased or decreased depending on control achieved.

Maximum usage rate must not exceed 2 lbs Proxitane WW-12 solution per ton (2000 lbs., dry basis) of pulp or paper produced.

Limitations, Restrictions, and Exceptions

INDOOR CLOSED LOOP, NON-POTABLE, NON-FOOD CONTACT WATER SYSTEMS

TREATMENT OF RAW AND PROCESS WATER (such as heat exchanger system water, boiler water, wet scrubber water, etc) -Proxitane WW -12 may be applied to water at the inlet of the water system or any other suitable point. Apply with either shock, intermittent, or continuous dosing. Shock dosing may be applied for 1 to 2 hours, as necessary, whereas intermittent dosing is applied for 2 to 15 minutes, 4 to 100 times per day. For either shock or intermittent dosing, apply 0.16 to 0.8 gallons Proxitane WW -12 per 1000 gallons of water producing a peak concentration of Proxitane WW -12 of 160 ppm to 800 ppm during dosing. This is approximately equivalent to a peak dose of 20 to 100 ppm 100% peracetic acid.

Method

[N. A.](#)

Rates

[field_rates 0](#)

field_rates 1

-

Timings

N. A.