

# **INDOOR CLOSED LOOP, NON-POTABLE, NON-FOOD CONTACT WATER SYSTEMS: TREATMENT OF COOLING WATER SYSTEMS**

General Information

## **DIRECTIONS FOR USE**

### **CONTROL OF ALGAL, FUNGAL, AND BACTERIAL GROWTH IN PULP AND PAPER MILL SYSTEMS FOR FOOD AND NON-FOOD CONTACT PAPER**

Proxitane WW -12 provides an effective means to treat various process waters for slime control. Dosage rates should be increased or decreased depending on control achieved.

Maximum usage rate must not exceed 2 lbs Proxitane WW-12 solution per ton (2000 lbs., dry basis) of pulp or paper produced.

Limitations, Restrictions, and Exceptions

### **INDOOR CLOSED LOOP, NON-POTABLE, NON-FOOD CONTACT WATER SYSTEMS**

TREATMENT OF COOLING WATER SYSTEMS (such as cooling towers, evaporative condensers, etc .) Severely fouled systems should be cleaned before treatment. Proxitane WW -12 should be added to the system directly and not mixed with any other chemicals or additives. Contamination with other chemicals could result in lack of efficacy. Add Proxitane WW -12 at a point in the system where uniform mixing and even distribution will occur such as the cooling tower basin sump. Shock doses may be applied for 1 to 2 hours, as necessary, whereas intermittent doses are applied for 5 to 60 minutes, 1 to 100 times per day. For either shock, intermittent or continuous dosing, apply 0.01 to 0.07 gallons Proxitane WW -12 solution per 1000 gallons of water. This will provide 10 to 70 ppm of Proxitane WW -12, or 1 to 9 ppm 100% peracetic acid. Repeat treatment as required to maintain control.

Method

[N. A.](#)

Rates

[field\\_rates 0](#)

[field\\_rates 1](#)

- 

Timings

[N. A.](#)